

REPUBLIC OF KENYA



UPDATED LEAST COST POWER DEVELOPMENT PLAN STUDY PERIOD: 2013 - 2033

MARCH 2013



TABLE OF CONTENTS

List of Acronyms	5
Technical Studies Team.....	6
Acknowledgements.....	7
1 INTRODUCTION.....	8
1.1 The updating methodology	9
1.2 Improvements from the previous update	9
2 LOAD FORECAST.....	11
2.1 Demand forecasting Methodology	11
2.1.1 General approach.....	11
2.1 Results of the forecast	11
3 LEAST COST GENERATION PLANNING.....	13
3.1 Methodology of Least Cost Generation Planning.....	13
3.2 Candidate Generation Sources	13
3.2.1 Implementation constraints for candidate projects.....	14
3.3 Committed generation projects.....	15
3.3.1 VALORAGUA Simulation Results	17
3.3.2 Short Run Marginal Cost Results (SRMC)	19
3.4 Long -term Optimization using WASP.....	20
3.5 Generation Tariffs	25
4 TRANSMISSION PLANNING.....	27
4.1 Methodology	27
4.2 Kenya Power Transmission System Development Plan 2013-2033	28
5 CONCLUSION AND IMPLEMENTATION PLAN.....	54
5.1 Conclusions	54
5.1.1 Load Forecasting.....	54
5.1.2 Least Cost Generation and Transmission plan.....	55

5.2	IMPLEMENTATION PLAN	55
5.2.1	Medium term 2014-2018.....	55
5.2.2	Long term 2018-2033	57

List of Table

Table 1: Energy forecast in GWh.....	11
Table 2: Committed generation projects.....	16
Table 3: Least Cost Expansion Program for the Base Case Analysis	20
Table 4: Installed Capacity by Type for the Least Cost Plan (Base case) MW	23
Table 5: Electricity Generation by Type (Base Case) GWh.....	24
Table 6: TRANSMISSION LINES INVESTMENT SEQUENCE	28
Table 7: TRANSFORMERS INVESTMENT SEQUENCE.....	38
Table 8: REACTIVE COMPENSATION INVESTMENT SEQUENCE.....	50

List of figures

Figure 1: Comparison of VALORAGUA Results with Five Year Actual Average Generation.....	18
Figure 2: Probability of Hydro Generation - System Configuration	18
Figure 3: Output of VALORAGUA Results Using Historical Inflow Data	19
Figure 4: Monthly SRMC and Hydropower Generation	19
Figure 5: Development of System Capacity for the Base Case under Reference Fuel Cost	24
Figure 6: Electricity Generation by Type (Base Case) in GWh.....	25
Figure 7: Evolution of Electricity Generation Tariffs in Kenya: 2012 - 2033.....	26

List of Acronyms

ERC	Energy Regulatory Commission
GDC	Geothermal Development Company
GDP	Gross Domestic Product
GoK	Government of Kenya
GT	Gas Turbine
GWh	Giga Watt hours
KenGen	Kenya Electricity Generating Company Limited
KenInvest	Kenya Investment Authority
KEPSA	Kenya Private Sector Alliance
KETRACO	Kenya Electricity Transmission Company
KPLC	Kenya Power & Lighting Company Limited
KNBS	Kenya National Bureau of Statistics
KNEB	Kenya Nuclear Electricity board
KWh	Kilo Watt hour
LCPDP	Least Cost Power Development Plan
LOLP	Loss of Load Probability
LRMC	Long Run Marginal Cost
MOEP	Ministry of Energy & Petroleum
MSD	Medium Speed Diesel
MW	Mega Watts
PV	Present Value
O & M	Operation and Maintenance
REA	Rural Electrification Authority
SRMC	Short Run Marginal Cost
TSDP	Transmission System Development Plan
WASP	Wien Automatic Simulation Package

Technical Studies Team

Name	Profession	Institution
Eng. Boniface Kinyanjui	Engineer	KPLC
Eng. Erastus Kiruja	Engineer	KPLC
Eng. Samson Akuto	Engineer	KETRACO
Eng. Tom Simiyu	Engineer	ERC
Mr. Adrian Kariuki	Engineer	GDC
Mr. Amos Nabaala	Engineer	KPLC
Mr. Anthony Karembu	Economist	KenGen
Mr. Bii Kiprotich	Engineer	ERC
Mr. Charles Njoroge	Economist	KETRACO
Mr. David Kariuki	Economist	ERC
Mr. Godfrey Kariuki	Economist	KETRACO
Mr. Harrison Sungu	Engineer	KETRACO
Mr. Kihara Mungai	Engineer	MOE
Mr. Shammah Kiptanui	Economist	GDC
Mr. Silas Cheboi	Economist	KPLC
Mr. Willis Ochieng	Hydrologists	KenGen
Ms. Ann Kiburi	Economist	KenGen
Ms. Beatrice Musyoka	Economist	KenGen
Ms. Grace Njeru	Economist	ERC
Ms. Winnie Njiraini	Economist	KNEB

Acknowledgements

Section 5(g) of the Energy Act No.4 of 2006 confers the responsibility of preparing Indicative Energy Plans on the Energy Regulatory Commission (ERC). The electric power sub-sector has been preparing the Least Cost Power Development Plan (LCPDP) as the sub-sector indicative plan. The purpose of the LCPDP is to guide stakeholders with respect to how the sub-sector plans to meet the energy needs of the nation for subsistence and development at least cost to the economy and the environment. The LCPDP as indicated in the Vision 2030 medium term plan aims at enhancing national power generation and supply by identifying new generation and supply sources to ensure that the national electric power supply exceeds 3,000MW by 2018.

To prepare the LCPDP, ERC set up a multi-stakeholder committee to undertake this task on an annual basis. The stakeholder committee includes representatives from the following key players: the Ministry of Energy and Petroleum (MOEP), Ministry of Devolution and Planning, National Development and Vision 2030, Kenya Electricity Generating Company (KenGen), Kenya Power and Lighting Company (KPLC), Geothermal Development Company (GDC), Rural Electrification Authority (REA), Kenya Electricity Transmission Company Limited (KETRACO), Kenya Nuclear Electricity Board (KNEB), Kenya National Bureau of Statistics (KNBS), Kenya Investment Authority (KenInvest), and the Kenya Private Sector Alliance (KEPSA) . This update has also benefitted from the technical assistance of the French government under the French Development Agency (AFD).

I wish to sincerely commend the technical study team for a job well done. I further wish to extend my gratitude to the Steering Committee and the AFD technical assistance for ably guiding the process. This process would not have been successful without the support of various stakeholders including: the Principal Secretary, Ministry of Energy & Petroleum, the Commissioners and staff of ERC and the CEO's and Boards of participating institutions. To them all I say: thank you very much.

Eng. Kaburu Mwirichia
Director General
Energy Regulatory Commission

Kenya Vision 2030 envisions an improved economic growth of 10% per annum by the year 2015. This growth will be supported by three pillars: Political, Social and Economic. Electricity consumption has a strong correlation to the national Gross Domestic Product (GDP) and therefore a multiplier effect on the economic pillar. Thus the country requires to plan for its electricity requirement to achieve the envisaged high GDP growth rate.

Over the years, the Government of Kenya through the Ministry of Energy & Petroleum has undertaken long term electricity planning through annual 20 year rolling Least Cost Power Development Plan (LCPDP). The plan is categorised into three key areas;

Load forecasting - Encompasses review of load forecast assumptions, pertinent variables, historical data set and methodology, taking cognizance of the future macro-economy;

Generation Planning - Involves review and update of the power system simulation data including committed generation projects, candidate plant types, capital and operational costs and system constraints to ensure system expansion is optimal.

Transmission Planning - Involves power system simulations to ensure optimal transmission system expansion and a stable power system.

The LCPDP is now updated biennially. The current report is an update of the LCPDP of 2011/2031 and covers the period 2013- 2033. The main objective of this update is to take into account updated assumptions, new technologies as well as market dynamics that may impact on future power expansion plan.

The specific objectives of this report are to:

- Update the load forecast taking into account the performance of the economy and the Vision 2030 flagship projects;
- Update historical data, literature, committed and candidate projects;
- Estimate Short-Run Marginal Cost (SRMC) and Long Run Marginal Cost (LRMC) for the generation system;
- Develop an optimum generation expansion plan for the system (least cost generation development plan);- and

- Prepare a power transmission system development plan in line with the least cost generation development plan.

1.1 The updating methodology

The update of the 2013-2033 LCPDP was undertaken by the Least Cost Planning Committee comprising of officers from the Ministry of Energy & Petroleum (MoEP), Kenya Electricity Generating Company (KenGen), Kenya Power and Lighting Company (KPLC), Geothermal Development Company (GDC), Rural Electrification Authority (REA), Kenya National Bureau of Statistics (KNBS) , the Ministry of State for National Planning and Vision 2030, Kenya Electricity Transmission Company Limited (KETRACO), Kenya Nuclear Electricity Board (KNEB), Kenya Vision 2030 Delivery Secretariat, Kenya Investment Authority (KenInvest) and the Kenya Private Sector Alliance (KEPSA). The LCPDP was updated with the technical assistance of Mr. Yves Le Texier, a technical assistant to the Ministry of Energy & Petroleum under the French Development Agency (AFD), and Mr. Francis Jensen, an expert on the Model for Analysis of Energy Demand (MAED) also under the AFD support.

First, the load forecast was developed using excel worksheets based on the MAED methodology and assumptions. The load forecast derived was then used as an input in the Wien Automatic Simulation Package (WASP) which was simulated to determine the least cost generation sequence to meet this demand. Finally the least cost generation plan was used to develop a transmission system model using the Power System Simulation for Engineering (PSSE) software, and simulations carried out to derive a suitable transmission system development plan.

This report is the abridged version of the detailed LCPDP 2013-2033 report. The detailed reports can be requested from ERC or any of the institutions in the energy sector.

1.2 Improvements from the previous update

The update of this LCPDP took cognizance of feedback received from key policy makers and various stakeholders. The following were considered in this report:

- a) The domestic category of the load forecast was separated into two regions covering Coast region and other regions in Kenya. The Coast region was treated separately because of its unique specific consumption arising from air conditioning.
- b) Elasticity coefficient factor of 1.5 for electricity demand to GDP.

- c) Reviewed population, urbanization and efficiency gains and technology in undertaking the demand forecast.
- d) The results of a household survey undertaken in the Nairobi region were used in developing the domestic demand forecast.
- e) Reviewed new potential demand arising from the effect of implementing Vision 2030 flagship projects and other investment projects which were considered to be included in the assumed 10% GDP growth rate.
- f) Least cost generation expansion simulations included new candidate projects
- g) The structure of the report improved with more information that is considered useful to those interested in the energy sector. The structure followed the guidelines provided by the AFD technical assistant to the Ministry of Energy & Petroleum.

2.1 Demand forecasting Methodology

2.1.1 General approach

The Model for Analysis of Energy Demand (MAED) developed by the International Atomic Energy Agency (IAEA) was used for energy demand forecasting in this update. As in previous LCPDP update, the MAED methodology was applied to design Microsoft Excel based models specific to the power sector in Kenya, which were used for the projections.

Three demand scenarios were developed based on assumptions which were defined to reflect both current and future economic and social outlook in the vision 2030. The low GDP forecast reflected a pessimistic case while the high scenario gives an optimistic case based on the vision 2030 aspiration while the reference scenario was the middle ground between the two scenarios.

2.1 Results of the forecast

The energy demand forecast and the peak load forecast are displayed in Table 1. The reference case ranges from 1370MW in 2012 to 3034MW in 2018 to 14446MW in 2030 and 21,075MW in 2033 while the energy demand increases from 8010GWh in 2012 to 17,719GWh in 2018 to 81,352GWh in 2030 and 118,680GWh in 2033.

Table 1: Energy forecast in GWh

YEAR	LOW SCENARIO			REFERENCE SCENARIO			HIGH SCENARIO		
	GWh	MW	Load factor	GWh	MW	Load factor	GWh	MW	Load factor
2012	8,010	1,370	66.76%	8,010	1,370	66.76%	8,010	1,370	66.76%
2013	9,387	1,606	66.74%	9,447	1,616	66.75%	9,499	1,625	66.74%
2014	10,450	1,785	66.84%	10,685	1,823	66.92%	10,850	1,851	66.92%
2015	11,572	1,978	66.78%	12,146	2,069	67.01%	12,514	2,130	67.06%
2016	12,739	2,184	66.59%	13,809	2,353	67.00%	14,478	2,462	67.12%
2017	13,989	2,410	66.26%	15,678	2,676	66.88%	16,740	2,849	67.07%
2018	15,275	2,649	65.83%	17,719	3,034	66.67%	19,282	3,288	66.94%
2019	16,689	2,913	65.39%	20,042	3,443	66.45%	22,236	3,799	66.82%
2020	18,242	3,207	64.94%	22,686	3,910	66.24%	25,671	4,395	66.68%
2021	19,941	3,530	64.48%	25,687	4,441	66.02%	29,657	5,087	66.56%
2022	21,847	3,895	64.03%	29,150	5,057	65.81%	34,357	5,904	66.43%

2023	23,933	4,298	63.56%	33,088	5,758	65.60%	39,827	6,857	66.30%
2024	26,229	4,745	63.10%	37,578	6,561	65.38%	46,208	7,972	66.17%
2025	28,754	5,242	62.62%	42,698	7,480	65.16%	53,657	9,275	66.04%
2026	31,532	5,793	62.14%	48,536	8,531	64.95%	62,355	10,801	65.91%
2027	34,588	6,404	61.65%	55,196	9,735	64.73%	72,515	12,587	65.77%
2028	37,951	7,084	61.16%	62,793	11,113	64.50%	84,389	14,680	65.62%
2029	41,651	7,839	60.66%	71,461	12,691	64.28%	98,270	17,132	65.48%
2030	45,723	8,641	60.41%	81,352	14,446	64.28%	114,502	19,940	65.55%
2031	50,204	9,541	60.07%	92,641	16,470	64.21%	133,492	23,248	65.55%
2032	55,135	10,538	59.73%	105,527	18,782	64.14%	155,712	27,122	65.54%
2033	59,135	11,318	59.65%	118,680	21,075	64.28%	179,850	31,237	65.73%

3.1 Methodology of Least Cost Generation Planning

The generation expansion planning involved:

- (a) Modeling the existing system in VALORAGUA software for hydro-thermal short term dispatch optimization model to project monthly hydropower generation and determine the short run marginal cost (SRMC) for the system;
- (b) Assembling existing power system model in WASP containing the demand forecast, the existing and candidate power generation, projected hydropower outputs and assumed economic costs and factors. The objective of the model was to carryout simulations to meet projected demand over planning period;
- (c) Carrying out WASP simulations to derive the optimal expansion plan;
- (d) Carrying out sensitivity analysis
- (e) Recommending a least cost generation expansion plan
- (f) Determining the LRMC for the expansion of the power system.
- (g) Evaluating the likely evolution of electricity tariffs over the planning period.

3.2 Candidate Generation Sources

Several potential power generation source/technologies were considered.

Hydropower - Two commercially viable large hydropower resource sites, Karura (90MW) and Low Grand Falls (140MW), were considered most promising for immediate development in the planning period.

Geothermal resources - mainly located within the Rift valley, and considered to have a potential between 7000-10000MW.

Wind power -The country has proven wind energy potential of as high as 346W/m² in parts of Eastern, North Eastern and Coast Provinces.

Gas Turbine -it was assumed that gas turbines would operate on imported natural gas, mainly to provide peaking capacity.

Medium Speed Diesel Plants – The plants were assumed to run on heavy fuel oil, but typical plants installed in the country can also operate on natural gas.

Coal Fired Power Plants –the candidate projects were assumed to run on imported or local coal

Nuclear Power Plants - Nuclear plants being considered for development in Kenya are 300MW, 600MW and 1000MW units. A pre-feasibility study was underway during preparation of this LCPDP.

Power Imports –a maximum of 2000MW cumulative imports was assumed based on the capacity of the HVDC line committed for development between Ethiopia and Kenya.

3.2.1 Implementation constraints for candidate projects

The constraints applied in Base Case WASP simulations are shown in the table below.

Table 2: Implementation Constraints

Candidate Generation Plant	Maximum	Date
Geothermal	Maximum 3 x 140MW in a year pre 2030 and 4 x 140MW from 2030	Earliest date 2018
Coal	Maximum per year 3 x 300MW before 2030 and 4 x 300MW from 2030	Earliest date 2018
Medium Speed Diesel(160MW)	Maximum per year 3 x 160MW	Earliest date 2018
Gas Turbines -GT (180MW)	Maximum per year 3 x 180MW and 4 x 100 MW after 2030	Earliest date 2018
Wind (100MW)	Maximum 3 x 100 MW and 4 x 100 MW after 2025	Earliest date 2018
Nuclear (600MW)	Maximum 2x 600 MW per year pre 2030	First candidate in 2022
Nuclear2 (1000MW)	Maximum 2 x 1000 MW	From 2030
Karura (90MW) hydro		Earliest date 2021
Low Grand Falls (140MW) hydro		Earliest date 2021
Imports (200MW)	2 x 200 MW	Earliest date 2018

3.3 Committed generation projects

There are a number of projects committed to improve generation in the immediate to mid-term. Estimated committed generation between 2012 and 2018 is 2,639MW as shown in table 2.

DRAFT

Table 3: Committed generation projects

Developer	Project Name	Type	Capacity (MW)	Est. date of commission (2011/12)
IPPs				
	Thika MSD Plant (Melec)	Medium Speed Diesel	87	July-2013
	Kitengela MSD Plant (Triumph)	Medium Speed Diesel	83	February -2014
	Athi River MSD Plant (Gulf)	Medium Speed Diesel	80	February -2014
	*Kwale International Sugar Company	Cogeneration (Bagasse)	18	Dec-2014
	*Aeolus – Kinangop	Wind	60	Dec-2014
	*Gura	Hydro	3	July-2015
	Orpower 4 Expansion phase I	Geothermal	36	Marc-2013, Under Commissioning, on Reliability Test Run.
	*Genpro	Hydro	3	July-2015
	Lake Turkana Wind Power	Wind	300	March-2016
	AGIL	Geothermal	140	March-2018
	Orpower 4 Expansion phase II	Geothermal	16	March-2014
	*Prunus	Wind	50	July-2015
	*Kipeto	Wind	100	July-2015
	*Hydel	Hydro	15	July 2015
	Ethiopia Import	Hydro	400	July-2017
	Sub-total (IPP)		1391	
KENGEN				
	Olkaria I	Geothermal	140	Sep-2014
	Olkaria IV Project	Geothermal	140	Jun-2014
	Olkaria Wellhead units	Geothermal	65	25MW-Jun 2014 40MW-Dec 2014
	Ngong Phase II	Wind	13.6	Dec-2014
	Ngong I Phase II	Wind	6.8	Nov-2014
	Kindaruma 3rd	Hydro	8	4MW - Achieved

Developer	Project Name	Type	Capacity (MW)	Est. date of commission (2011/12)
	unit & rehab of unit 1&2			4MW Jul-2013
	Isiolo wind project (Phase I)	Wind	50	Jun-2017
	Olkaria I unit 6	Geothermal	70	Jun-2015
	Olkaria V	Geothermal	140	Jun-2017
	Eburru	Geothermal	25	Jun-2017
	Sub-total (Kengen)		658.4	
GDC				
	Well head Generation	Geothermal	10	2014
	Well head Generation Units	Geothermal	30	2014
	Bogoria - Silali Well Head Generation Units	Geothermal	75	2017
	Bogoria - Silali Well Head Generation Units	Geothermal	75	2018
	Menengai Phase I Power Project	Geothermal	400	300MW May-2017 100MW Sep-2017
	Sub-total (IPP/Kengen)		590	
	Total		2639.4	

*Feed in Tariff project

3.3.1 VALORAGUA Simulation Results

Figures 1, 2 and 3 provide the results from VALORAGUA Simulation tool. Figure 1 compares the VALORAGUA average annual output and the actual average output over a 5-year period. The results obtained from the model closely track the actual 5-year generation average.

Figure 1: Comparison of VALORAGUA Results with Five Year Actual Average Generation





Figure 2: Probability of Hydro Generation - System Configuration




Based on the results of the VALORAGUA simulation, the probability of exceeding a given level of generation from hydro power plants can be determined from Figure 2 above. From the figure, it is evident that there is a 7% probability of generating 3,500 GWh or more annually which corresponds to the wet hydrological year of 1982. Likewise, there is a 50% probability of generating 3,300GWh or more annually which corresponds to the average hydrological year

of 1992. In addition, there is a 90% probability of generating 3,100 GWh or more annually which corresponds to the dry hydrological year of 1984.

Figure 3 below shows the annual average generation from hydro power plants using historical inflow data for the period 1980 to 2009. The average generation for the period was 3280 GWh.


Figure 3: Output of VALORAGUA Results Using Historical Inflow Data



3.3.2 Short Run Marginal Cost Results (SRMC)

Figure 4 shows relationship between the SRMC and average monthly hydropower generation.

Figure 4: Monthly SRMC and Hydropower Generation



From the figure above it is apparent that the SRMC varies from month to month ranging from a high of 36.3 US cents/kWh in February to a low of 11 US cents/kWh in May. This is due to the inverse correlation between the SRMC of the system and energy generation from hydro power plants due to the substitution effect of thermal generation for hydro based generation during the wet seasons of the year and vice versa. Due to the high operation and maintenance costs of thermal based plants including fuel costs, the SRMC of the system increases as hydro capacity declines during short rains (September to November) and decreases as hydro capacity increase in the long rains (April to July). The average SRMC from the results was 20.1 US cents/kWh.

3.4 Long -term Optimization using WASP

System expansion analyses were performed using WASP to determine the least-cost path to meet the projected demand. The least cost development plan based on the optimum solution is presented in Table 4.

Table 4: Least Cost Expansion Program for the Base Case Analysis

Year ending 30th June	Configuration			Type	Added Capacity MW	Total Capacity MW	System Peak MW	Reserve Margin MW	Reserve Margin as % of Peak
2012						1,682	1,370	312	23%
2013	1	x	87	THIKA	MSD	87			
	2	x	18	ORP4	Geothermal	36	1,805	1,616	189
2014	1	x	16	ORP4	Geothermal	16			
	1	x	6.8	Ngong	Wind	6.8			
	2	x	6.8	Ngong	Wind	13.6			
	2	x	70	OLK4	Geothermal	140			
	5	x	16	Triumph	MSD	80			
	5	x	16.6	GULF	MSD	83			
	2	x	70	OLK1B	Geothermal	140			
	4	x	5	OLKWH	Geothermal	20			
	8	x	5	MENW	Geothermal	40			
	10	x	-12	AGRKO	EMERG MSD	-120	2,228	1,823	405
2015	10	x	5	OLKWH	Geothermal	50			
	5	x	10	PRUNUS	WIND	50			
	1	x	21	SMHYD	HYDRO	21			
	10	x	10	KIPETO	WIND	100			
	1	x	18	Kwale	congen	18			
	6	x	10	AELOUS	WIND	60	2,528	2,069	459

Year ending 30th June	Configuration			Type	Added Capacity MW	Total Capacity MW	System Peak MW	Reserve Margin MW	Reserve Margin as % of Peak
2016	2	x	-30	KGT1&2	GT-KERO	-60			
	3	x	-15.1	OLK1	Geothermal	-45.3			
	1	x	70	OLK1B	Geothermal	70	2,493	2,353	140 6%
2017	1	x	26	Eburru	Geothermal	26			
	30	x	10	LTWP	Wind	300			
	5	x	10	Isiolo	Wind	50			
	4	x	100	Menengai	Geothermal	400			
	1	x	75	SILALI	Geothermal	70			
	2	x	200	Import	Import	400			
	8	x	-5	MENW	Geothermal	-40			
	2	x	70	OLKV	Geothermal	140	3,844	2,676	1,168 44%
2018	1	x	75	SILALI	Geothermal	75			
	1	x	200	Import	Import	200			
	2	x	70	Agil	Geothermal	140			
	3	x	15.3	OLK1	Geothermal	45.9	4,304	3,034	1,270 42%
2019	1	x	140	GEOT	Geothermal	140			
	10	x	-7.4	TSAVO	MSD	-74			
	1	x	200	IMPORT	IMPORT	200			
	10	x	-5.6	IBR1	MSD	-56			
	1	x	-26	Mumias	Congen	-26	4,488	3,443	1,045 30%
2020	1	x	100	Wind	Wind	100			
	3	x	140	GEOT	Geothermal	420	5,008	3,910	1,098 28%
2021	2	x	180	GT-NGAS	GT	360			
	1	x	100	Wind	Wind	100			
	1	x	140	GEOT	Geothermal	140	5,608	4,441	1,167 26%
2022	2	x	140	GEOT	Geothermal	280			
	2	x	180	GT-NGAS	GT	360			
	3	x	100	Wind	wind	300	6,548	5,057	1,491 29%
2023	1	x	140	GEOT	Geothermal	140			
	1	x	180	GT-NGAS	GT	180			
	1	x	600	Nuclear	Nuclear	600	7,468	5,758	1,710 30%
2024	3	x	140	GEO	Geothermal	420			
	1	x	300	COAL	Coal	300			
	2	x	100	Wind	Wind	200	8,388	6561	1,827 28%
2025	3	x	140	GEOT	Geothermal	420			
	6	x	-10	KDP1	MSD	-60			
	1	x	100	Wind	Wind	100			
	1	x	180	GT-NGAS	GT	180			
	2	x	200	IMPORT	IMPORT	400	9,428	7,480	1,948 26%
2026	1	x	200	IMPORT	IMPORT	200			
	3	x	180	GT-NGAS	GT	540			

Year ending 30th June	Configuration			Type	Added Capacity MW	Total Capacity MW	System Peak MW	Reserve Margin MW	Reserve Margin as % of Peak	
	3	x	140	GEOT	Geothermal	420	10,588	8,531	2,057	24%
2027	3	x	140	GEOT	Geothermal	420				
	3	x	-12	ORP4A	Geothermal	-36				
	3	x	-4	ORP4B	Geothermal	-12				
	1	x	300	COAL	COAL	300				
	1	x	200	IMPORT	IMPORT	200				
	2	x	100	WIND	WIND	200	11,656	9,735	1,921	20%
2028	3	x	100	WIND	WIND	300				
	2	x	300	COAL	COAL	600				
	1	x	180	GT-NGAS	GT	180				
	5	x	-18	RABAI		-90				
	3	x	140	GEOT	Geothermal	420				
	1	x	200	IMORT	IMPORT	200	13,266	11,113	2,153	19%
2029	3	x	140	GEOT	Geothermal	420				
	3	x	300	COAL	COAL	900				
	3	x	-35	OLK2	Geothermal	-105				
	2	x	180	GT-NGAS	GT	360				
	2	x	100	Wind	Wind	200				
	1	x	200	IMPORT	IMPORT	200	15,241	12,691	2,550	20%
2030	4	x	140	GEOT	Geothermal	560				
	1	x	100	Wind	Wind	100				
	2	x	180	GT-NGAS	GT	360				
	1	x	1000	Nuclear	Nuclear	1000	17,261	14,446	2,815	19%
2031	3	x	180	GT-NGAS	GT	540				
	4	x	300	COAL	COAL	1200				
	4	x	140	GEOT	Geothermal	560	19,561	16,470	3,091	19%
2032	4	x	140	GEOT	Geothermal	560				
	4	x	300	COAL	COAL	1200				
	7	x	-16.5	KDP3	MSD	-115.5				
	4	x	180	GT-NGAS	GT	720				
	1	x	160	MSD	MSD	160	22,086	18,782	3,304	18%
2033	4	x	140	GEOT	Geothermal	560				
	3	x	300	COAL	COAL	900				
	7	x	-7.5	IBR2	MSD	-52.5				
	1	x	180	GT-NGAS	GT	180				
	1	x	1000	NUCL	NUCLEAR	1000	24,673	21,075	3,598	17%

Key: NUCL-Nuclear power, ORP4 -Orpower 4,OKWH-Olkaria Well Head, GEOT- Geothermal, , SANG - Sangoro, , ARMC - Athi River Mining Coal, THK - Thika MSD, LTWP- Lake Turkana Wind, KIND -Kindaruma, IBR-Iberafrica, , KGT-Kipevu GT, , LGF-Lower Grand Falls, GT- Gas turbines Natural Gas, MSD- Medium speed Diesel, OLK1- Olkaria 1, MENW - Menengai well head

Table 5 and Figure 5 show the installed capacity by fuel type for the least cost plan over the planning period. The results indicate that future capacity is likely to be dominated by Geothermal, Coal, GT (N-GAS), Nuclear and Wind.

Table 5: Installed Capacity by Type for the Least Cost Plan (Base case) MW

Year	Hydro	Nuclear	MSD	Import	Cogen	GT-KERO	GT-NG	Geothermal	Coal	Wind	Total	Peak Load	Reserve Margin	% LOLP
2012	814	-	568	-	26	60	-	209	-	5	1,682	1370	22.7	4.13
2013	814	-	655	-	26	60	-	245	-	5	1,805	1616	11.7	13.934
2014	814	-	698	-	26	60	-	604	-	26	2,228	1823	22.1	0.397
2015	835	-	698	-	44	60	-	655	-	236	2,528	2069	22.1	2.008
2016	835	-	698	-	44	-	-	680	-	236	2,493	2353	5.9	31.855
2017	835	-	698	400	44	-	-	1,281	-	586	3,844	2676	43.6	0.003
2018	835	-	698	600	44	-	-	1,541	-	586	4,304	3034	41.8	0.001
2019	835	-	568	800	18	-	-	1,681	-	586	4,488	3443	30.3	0.075
2020	835	-	568	800	18	-	-	2,101	-	686	5,008	3910	28	0.099
2021	835	-	568	800	18	-	360	2,241	-	786	5,608	4441	26.2	0.166
2022	835	-	568	800	18	-	720	2,521	-	1,086	6,548	5057	29.5	0.105
2023	835	600	568	800	18	-	900	2,661	-	1,086	7,468	5758	29.7	0.169
2024	835	600	568	800	18	-	900	3,081	300	1,286	8,388	6561	27.8	0.256
2025	835	600	508	1,200	18	-	1,080	3,501	300	1,386	9,428	7480	26	0.248
2026	835	600	508	1,400	18	-	1,620	3,921	300	1,386	10,588	8531	24.1	0.195
2027	835	600	508	1,600	18	-	1,620	4,289	600	1,586	11,656	9735	19.7	0.744
2028	835	600	418	1,800	18	-	1,800	4,709	1,200	1,886	13,266	11113	19.4	0.968
2029	835	600	418	2,000	18	-	2,160	5,024	2,100	2,086	15,241	12691	20.1	0.801
2030	835	1,600	418	2,000	18	-	2,520	5,584	2,100	2,186	17,261	14446	19.5	0.844
2031	835	1,600	418	2,000	18	-	3,060	6,144	3,300	2,186	19,561	16470	18.8	0.747
2032	835	1,600	463	2,000	18	-	3,780	6,704	4,500	2,186	22,086	18782	17.6	0.791
2033	835	2,600	410	2,000	18	-	3,960	7,264	5,400	2,186	24,673	21075	17.1	0.829

Figure 5: Development of System Capacity for the Base Case under Reference Fuel Cost





Table 6 and figure 6 show the energy outputs for the base case. Thermal power plants are expected to mainly provide the required system reserve capacity.

Table 6: Electricity Generation by Type (Base Case) GWh

YEAR	Hydro	Nuclear	MSD	Import	Cogen	GT-Kero	GT-NG	Geo-thermal	Coal	Wind	TOTAL
2012	3168	0	3190	0	221	55	0	1733	0	17	8384
2013	3168	0	4217	0	223	146	0	2033	0	17	9804
2014	3168	0	2767	0	209	3	0	4971	0	67	11185
2015	3204	0	3141	0	346	13	0	5406	0	576	12686
2016	3204	0	4237	0	362	0	0	5644	0	576	14023
2017	3204	0	94	1390	53	0	0	9915	0	1764	16420
2018	3204	0	38	1392	16	0	0	11689	0	1764	18103
2019	3204	0	75	2428	9	0	0	13062	0	1764	20542
2020	3204	0	74	1993	8	0	0	16037	0	2011	23327
2021	3204	0	139	3206	25	0	181	17482	0	2259	26496
2022	3204	0	213	3572	49	0	439	19694	0	3001	30172

2023	3204	2912	121	2537	24	0	389	20811	0	3001	32999
2024	3204	2931	113	3004	38	0	379	24081	354	3496	37600
2025	3204	2986	97	4573	28	0	403	27541	293	3744	42869
2026	3204	3064	136	6271	47	0	766	31182	478	3744	48892
2027	3204	3168	193	7963	73	0	1011	34483	1450	4238	55783
2028	3204	3195	51	9242	82	0	1059	37857	2995	4981	62666
2029	3204	3384	41	10903	95	0	1185	40950	6334	5476	71572
2030	3204	8903	39	10525	90	0	1391	45760	5827	5723	81462
2031	3204	9424	34	11075	100	0	1685	50592	11048	5723	92885
2032	3204	10057	37	11602	105	0	2376	55373	17447	5723	105924
2033	3204	16159	31	11414	104	0	2098	60066	19493	5723	118292


Figure 6: Electricity Generation by Type (Base Case) in GWh



3.5 Generation Tariffs

Based on the developed least cost generation plan an analysis of the evolution of generations tariffs was undertaken. The results are indicated in figure 7 below. If the plan is implemented as suggest the tariffs will continue declining to about 9.7US cents/kWh. As indicated in the graph the current tariffs are the highest the subsector will experience if the proposed plan is implemented.

Figure 7: Evolution of Electricity Generation Tariffs in Kenya: 2012 - 2033



4.1 Methodology

This transmission plan development employs the target network concept of transmission planning which ensures a coordinated investment strategy and therefore optimal network development using the Least Cost Planning concept. The transmission planning involved:

- Developing a set of transmission network solutions for the planning horizon year 2033 to be considered in selection and recommendation of a final target network on which the transmission plan shall be based.
- Preparing detailed alternative transmission development sequences for comparison and determination of the least cost transmission plan
- Developing and presenting cost estimates for the planned investments

The Transmission investment sequences were established by creating and optimizing network models at 5 year intervals between 2015 and 2030, with each of the investments conforming to the 2033 target network requirements. This was done by starting with the 2033 target network and developing 2025, 2020, and 2015 network models in reverse sequence by switching generators and loads as per the generation development plan and load forecast, and equipment not required as a result. Network models for each of the snapshot years were optimized through load flow, contingency and short circuit studies to ensure the transmission criteria was complied with at every stage.

The resultant transmission Lines, Substations and Reactive compensation requirements for the system are tabulated in tables 7, 8 and 9 below.

4.2 Kenya Power Transmission System Development Plan 2013-2033

Table 7: TRANSMISSION LINES INVESTMENT SEQUENCE

YEAR	TRANSMISSION LINE	CIRCUIT NO.	LENGTH (KM)	COST '000 USD		
				LINES	BAYS	NEW S/S
2013	KINDARUMA TOFF_MANGU_132kV	1	17	1646	783	4193
	MASINGA TOFF_KUTUS_132kV	1	12	1162	783	4193
	OLKARIA II_OLKARIA 1A_220kV	1	4	387	1566	0
	MANGU_GATUNDU_132kV	1	20	1936	1566	4193
	MANGU_GITHAMBO_132kV	1	43	4162	1566	4193
	JUJA RD TOFF_MANGU_132kV	1	17	1646	783	0
	KIGANJO TOFF_KUTUS_132kV	1	12	1162	783	0
	LESSOS_KAPSABET_132kV	1	30	2904	1566	4193
	LESSOS MAKUTANO_132kV*	1	0	0	783	4193
	LANET_MAKUTANO_132kV*	1	0	0	783	4193
	MARIKANI_RABAI_220kV	1	33	7260	2560	0
	MARIKANI_RABAI_220kV	2	33	0	2926	0
	ISINYA_EMBAKASI_220kV	1	34	9180	2560	0
	ISINYA_EMBAKASI_220kV	2	34	0	2560	0
	ISINYA_MARIKANI_220kV**	1	429	137280	4000	0
	ISINYA_MARIKANI_220kV	2	429	0	4000	0
	RABAI_MALINDI_220kV	1	97	15520	2560	6863
	MALINDI_GARSEN_220kV	1	117	18720	2560	6863
	GARSEN_LAMU_220kV	1	108	17280	2560	6863
2014	KINDARUMA_MWINGI_132kV	1	32	3098	1566	4193
	OLKARIA 1_OLKARIA1A_132kV	1	3	290	1566	0
	OLKARIA1_OLKARIA1E_132kV	1	1	106	1566	0
	DOMES_OLKARIA1A_132kV	1	6	581	1566	0
	NANYUKI_ISIOLO_132kV	1	64	6195	1566	0
	ISIOLO_MERU_132kV	1	32	3098	1566	4193
	LESSOS_NAKURU WEST_132kV*	1	0	0	1566	4193
	LANET_NAKURU WEST_132kV*	1	0	0	1566	0
	LANET_NAKURU WWEST_132kV*	2	0	0	1566	0

YEAR	TRANSMISSION LINE	CIRCUIT NO.	LENGTH (KM)	COST '000 USD		
				LINES	BAYS	NEW S/S
	KYENI_ISHIARA_132kV	1	15	1452	1566	4193
	KYENI_KUTUS_132kV	1	18	1742	1566	0
	ISHIARA_MERU_132kV*	1	0	0	1566	0
	KISII_AWENDO_132kV	1	44	4259	1566	4193
	NAKURU WEST MAKUTANO_132kV*	2	0	0	1566	0
	MWINGI_GARISSA_132kV	1	192	18586	1566	4193
	ISINYA_SUSWA_220kV**	1	100	32000	5000	0
	ISINYA_SUSWA_220kV**	2	100	0	5000	0
	ISINYA_ATHI_220kV	1	20	5387	2560	6863
	ISINYA_ATHI_220kV	2	20	0	2560	0
	TURKWEL_KAINUK_220kV	1	0	0	2560	6863
	OLKARIA II_SUSWA_220kV*	1	0	0	1280	0
	OLKARIA II_SUSWA_220kV*	2	0	0	1280	0
	OLKARIA II_OLKARIA1E_220kV	1	3	810	2560	0
	OLKARIA II_OLKARIA1E_220kV	2	3	0	2560	0
	SUSWA_OLKARIA1E_220kV	1	27	7290	2560	0
	SUSWA_OLKARIA1E_220kV	2	27	0	2560	0
	SUSWA_NBNORTH_220kV*	1	0	0	1280	0
	SUSWA_NBNORTH_220kV*	2	0	0	1280	0
	SUSWA_OLKARIAIV_220kV	1	25	6750	2560	0
	SUSWA_OLKARIAIV_220kV	2	25	0	2560	0
	SUSWA_NGONG_220kV	1	50	13500	2560	6863
	SUSWA_NGONG_220kV	2	50	0	2560	
	DANDORA_KOMOROCK_220kV	1	3	810	2560	6863
	DANDORA_KOMOROCK_220kV	2	3	0	2560	
	DANDORA THIKA RD_220kV*	1	0	0	2560	6863
	DANDORA THIKA RD_220kV*	2	0	0	2560	0
	EMBAKASI_ATHI_220kV	1	18	4860	2560	6863
	EMBAKASI_ATHI_220kV	2	18	0	2560	0
	NBNORTH_THIKARD_220kV*	1	0	0	2560	0
	NBNORTH_THIKARD_220kV*	2	0	0	2560	0
	LESSOS_TORORO_220kV**	1	127	40640	4000	0
	LESSOS_TORORO_220kV**	2	127	0	4000	0
2015	OLKARIA_NAROK_132kV	1	68	6582	1566	4193

YEAR	TRANSMISSION LINE	CIRCUIT NO.	LENGTH (KM)	COST '000 USD		
				LINES	BAYS	NEW S/S
	MTWAPA_KILIFI_132kV	1	25	2381	1566	4193
	MTWAPA_BAMBURI_132kV	1	25	2381	1566	0
	RABAI_BAMBURI_132kV	1	25	3870	1566	0
	NANYUKI_NYAHURURU_132kV	1	79	7647	1566	4193
	CHEMOSIT_SOTIK_132kV*	1	0	0	783	0
	KISII_SOTIK_132kV*	1	0	0	1566	0
	CHOGORIA_ISHIARA_132kV	1	40	3872	1566	4193
	LESSOS_KABARNET_132kV	1	65	6292	1566	4193
	NAIVASHA_AEOLOUS WIND_132kV	1	30	2904	1566	0
	SULTAN_KONZA_132kV*	1	0	0	1566	0
	SULTAN_WOTE_132kV	1	37	3582	1566	4193
	SULTAN_KITUI_132kV	1	86	8325	1566	4193
	VOI_TAVETA_132kV	1	90	8712	1566	4193
	GALU_LUNGA LUNGA_132kV	1	50	4840	1566	4193
	SONDU_HOMABAY_132kV	1	70	6776	1566	4193
	MERU_ISIOLO_132kV	1	32	3098	1566	4193
	MERU_MAUA_132kV	1	50	4840	1566	4193
	BOMET_SOTIK_132kV	1	30	2904	1566	4193
	NYAHURURU_RUMURUTI_132kV	1	20	1936	1566	9568
	KONZA_ISINYA_132kV	1	35	3388	1566	0
	KONZA_MACHAKOS_132kV	1	20	1936	1566	4193
	WAJIR_GARISSA_132kV	1	300	29040	1566	4193
	KAJIADO_ISINYA_132kV	1	10	968	1566	4193
	KAJIADO_NAMANGA_132kV	1	90	8712	1566	4193
	SULTAN_LOITOKITOK_132kV	1	120	11616	1566	4193
	AWENDO_NDHIWA_132kV	1	50	4840	1566	4193
	RUMURUTI_MARALAL_132kV	1	148	14326	1566	4193
	MWINGI_KITUI_132kV	1	30	2904	1566	4193
	HOMABAY_NDHIWA_132kV	1	15	1452	1566	4193
	ISINYA_KIPETO_220kV	1	30	4800	2560	0
	MATASIA_NGONG_220kV	1	25	6750	2560	6863
	MATASIA_NGONG_220kV	2	25	0	2560	0
	KAINUK_ORTUM_220kV	1	80	12800	2560	6863
	OLKARIAII_LESSOS_220kV**	1	203	64960	2560	6863
	OLKARIAII_LESSOS_220kV**	2	203	0	2560	0

YEAR	TRANSMISSION LINE	CIRCUIT NO.	LENGTH (KM)	COST '000 USD		
				LINES	BAYS	NEW S/S
	LESSOS_KISUMU_220kV**	1	103	32960	2560	6863
	LESSOS_KISUMU_220kV**	2	103	0	2560	0
	GARSEN_HOLA_220kV	1	96	15360	2560	6863
	GARISSA_HOLA_220kV	1	144	23040	2560	6863
	TURKWEL_KITALE_220kV	1	108	17280	2560	0
	ORTUM_KITALE_220kV	1	30	4800	2560	6863
2020	ELDORET_MOI BRKS_132kV*	1	18	0	1566	4193
	KIGANJ0_MURANGA_132kV	1	38	3630	1566	4193
	MUSAGA_BUNGOMA_132kV	1	30	2904	1566	4193
	LANET_GILGIL_132kV*	1	0	0	1566	4193
	LANE1_GILGIL_132kV*	2	0	0	1566	0
	NAIVSHA_GILGIL_132kV*	1	0	0	1566	0
	NAIVSHA_GILGIL_132kV*	2	0	0	1566	0
	MUMIAS_CHAVAKALI_132kV	1	30	2904	1566	4193
	NYAHURURU_KABARNET_132kV	1	90	8712	1566	4193
	KABARNET_KAPSOWAR_132kV	1	33	3146	1566	4193
	NAKURU WEST_KERINGET_132kV*	1	0	0	1566	4193
	AWENDO_MIGORI_132kV	1	30	2904	1566	4193
	KITALE_MOI BRKS_132kV*	1	42	0	1566	4193
	GITHAMBO_MURANGA_132kV	1	38	3630	1566	4193
	MAKUTANO_KERINGET_132kV	1	13	0	1566	0
	MWINGI_KITUI_132kV	1	30	2904	1566	0
	MARIAKANI_LIKONI_220kV	1	44	7040	2560	6863
	MARIAKANI_MARIAKANI_220kV	1	5	1350	2560	6863
	MARIAKANI_MARIAKANI_220kV	2	5		2560	0
	ISINYA_DANDORA_220kV	1	34	9180	2560	0
	ISINYA_DANDORA_220kV	2	34	0	2560	0
	ISINYA_MALILI_220kV**	1	90	28800	2560	6863
	ISINYA_MALILI_220kV**	2	90	0	2560	0
	ISINYA_ATHI_220kV	3	20	3771	2560	0
	MATASIA_PIPELINE_220kV	1	10	2700	2560	6863
	MATASIA_PIPELINE_220kV	2	10	0	2560	0
	MATASIA_ATHI_220kV	1	25	6750	2560	0
	MATASIA_ATHI_220kV	2	25	0	2560	
	KIAMBERE_MUTONGA_220kV	1	40	8800	2560	0

YEAR	TRANSMISSION LINE	CIRCUIT NO.	LENGTH (KM)	COST '000 USD		
				LINES	BAYS	NEW S/S
	KIAMBERE_MUTONGA_220kV	2	40	0	2560	0
	OLKARIA II_RONGAI_220kV*	1	0	0	2560	6863
	OLKARIA II_RONGAI_220kV*	2	0	0	2560	0
	SUSWA_SUSWA GEN_220kV	1	10	2700	2560	0
	SUSWA_SUSWA GEN_220kV	2	10		2560	0
	SUSWA_RUMURUTI_220kV**	1	101	32336	2560	68630
	SUSWA_RUMURUTI_220kV**	2	101	0	2560	
	ELDORET NORTH_ELDORET_220kV	1	10	1600	2560	6863
	GILGIL_NAIVASHA_220kV	1	30	8141	2560	6863
	GILGIL_NAIVASHA_220kV	2	30	0	2560	0
	GILGIL_LANET_220kV	1	37	9950	2560	6863
	GILGIL_LANET_220kV	2	37	0	2560	0
	KITALE_ORTUM_220kV	1	40	8800	2560	6863
	KISUMU EAST_1LESSO2_220kV*	1	0	0	2560	6863
	KISUMU EAST_1LESSO2_220kV*	2	0	0	2560	0
	KISUMU EAST_MUHORONI_220kV	1	28	6160	2560	6863
	KISUMU EAST_MUHORONI_220kV	2	28	0	2560	0
	KISUMU EAST_KISUMU_220kV*	1	0	0	2560	0
	KISUMU EAST_KISUMU_220kV*	2	0		2560	0
	MUSAGA_LESSOS_220kV*	1	0	0	2560	6863
	MUSAGA_LESSOS_220kV*	2	0	0	2560	0
	MUSAGA_TORORO_220kV*	1	0	0	2560	0
	MUSAGA_TORORO_220kV*	2	0	0	2560	0
	LESSOS_ELDORET_220kV	1	30	6600	2560	0
	LESSOS_RONGAI_220kV	1	0	0	2560	0
	LESSOS_RONGAI_220kV	2	0	0	2560	0
	MUHORONI_CHEMOSIT_220kV	1	31	6754	2560	6863
	MUHORONI_CHEMOSIT_220kV	2	31	0	2560	0
	KATHWANA_MUTONGA_220kV	1	20	4400	2560	6863
	KATHWANA_MUTONGA_220kV	2	20	0	2560	0
	JUJA RD_RUARAKA_220kV	1	15	4050	2560	6863
	JUJA RD_RUARAKA_220kV	2	15	0	2560	0
	RUARAKA_NAIVASHA_220kV	1	75	20250	2560	6863
	RUARAKA_NAIVASHA_220kV	2	75	0	2560	0
	NAIVASHA_KINANGOP WIND_220kV	1	30	6600	2560	0
	LANET_RONGAI_220kV	1	25	6750	2560	6863

YEAR	TRANSMISSION LINE	CIRCUIT NO.	LENGTH (KM)	COST '000 USD		
				LINES	BAYS	NEW S/S
	LANET_RONGAI_220kV	2	25	0	2560	0
	LOYANGALANI_RUMURUTI_220kV***	1	329	105264	2560	6863
	LOYANGALANI_RUMURUTI_220kV***	2	329	0	2560	0
	MARIKANI_ISINYA_400kV***	1	0	0	5000	9568
	MARIKANI_ISINYA_400kV***	2	0	0	5000	0
	ISINYA_ARUSHA_400kV	1	100	42000	4000	0
	ISINYA_ARUSHA_400kV	2	100	0	4000	0
	ETHIOPIA_KENYA_500kV HVDC	1	612	762000	2500	9568
	ETHIOPIA_KENYA_500kV HVDC	2	612	0	2500	0
	SILALI_PAKA_400kV	1	35	11200	4000	0
	SILALI_PAKA_400kV	2	35	0	4000	0
	PAKA_KOROSI_400kV	1	20	6400	4000	0
	PAKA_KOROSI_400kV	2	20	0	4000	0
	KOROSI_BOGORIA_400kV	1	50	16000	4000	0
	KOROSI_BOGORIA_400kV	2	50	0	4000	
	MENENGAI_RONGAI_400kV	1	20	6400	4000	9568
	MENENGAI_RONGAI_400kV	2	20		4000	0
	ISINYA_ARUSHA_400kV	1	200	64000	4000	0
	ISINYA_ARUSHA_400kV	2	200	0	4000	0
	ISINYA_PIPELINE_400kV	1	50	0	4000	9568
	ISINYA_PIPELINE_400kV	2	50	0	4000	0
	BOGORIA_RONGAI_400kV	1	60	19200	4000	0
	BOGORIA_RONGAI_400kV	2	60	0	4000	
	LONGONOT_SUSWA_400kV	1	20	6400	4000	0
	LONGONOT_SUSWA_400kV	2	0	0	4000	
	SUSWA_PIPELINE_400kV*	1	0	0	4000	0
	SUSWA_PIPELINE_400kV*	2	0	0	4000	0
2025	ISINYA_KOMOROCK_220kV	1	40	10800	2560	6863
	ISINYA_KOMOROCK_220kV	2	40		2560	0
	GALU_LIKONI_220kV	1	30	8100	2560	6863
	GALU_LIKONI_220kV	2	30	0	2560	0
	DONGOKUNDU_LIKONI_220kV	1	8	2160	2560	6863
	DONGOKUNDU_LIKONI_220kV	2	8	0	2560	0
	DONGOKUNDU_MBARAKI_220kV	1	10	2700	2560	6863
	DONGOKUNDU_MBARAKI_220kV	2	10	0	2560	0

YEAR	TRANSMISSION LINE	CIRCUIT NO.	LENGTH (KM)	COST '000 USD		
				LINES	BAYS	NEW S/S
	MATASIA_LANGATA_220kV	1	20	5400	2560	6863
	MATASIA_LANGATA_220kV	2	20	0	2560	0
	CITY SQR_EMBAKASI_220kV	1	17	22275	2560	6863
	CITY SQR_EMBAKASI_220kV	2	17	0	2560	0
	KARI WAIYAKI WAY_NBNORTH_220kV	1	15	20250	2560	6863
	KARI WAIYAKI WAY_NBNORTH_220kV	2	15	0	2560	0
	DANDORA_JUJA RD_220kV	1	3	810	2560	6863
	DANDORA_JUJA RD_220kV	2	3	0	2560	
	KOMOROCK_KAMULU_220kV	1	15	4050	2560	6863
	KOMOROCK_KAMULU_220kV	2	15	0	2560	0
	ISIOLO_MERU_220kV	1	35	7700	2560	6863
	ISIOLO_MERU_220kV	2	35	0	2560	0
	ISIOLO_NANYUKI_220kV	1	70	15400	2560	6863
	ISIOLO_NANYUKI_220kV	2	70	0	2560	0
	MURANGA THIKA_220kV	1	46	12285	2560	6863
	MURANGA THIKA_220kV	2	46	0	2560	0
	MURANGA_KIGANJO_220kV	1	45	12150	2560	6863
	MURANGA_KIGANJO_220kV	2	45	0	2560	0
	MERU_MUTONGA_220kV	1	70	15400	2560	6863
	MERU_MUTONGA_220kV	2	70	0	2560	0
	MUTONGA_LG FALLS_220kV	1	20	4400	2560	6863
	MUTONGA_LG FALLS_220kV	2	20	0	2560	0
	MANGU_THIKA_220kV	1	20	5265	2560	6863
	MANGU_THIKA_220kV	2	20		2560	0
	MANGU_THIKA RD_220kV	1	20	5400	2560	6863
	MANGU_THIKA RD_220kV	2	20	0	2560	0
	NANYUKI_KIGANJO_220kV	1	52	13905	2560	6863
	NANYUKI_KIGANJO_220kV	2	52	0	2560	0
	NANYUKI_RUMURUTI_220kV**	1	100	27000	2560	6863
	NANYUKI_RUMURUTI_220kV**	2	100	0	2560	0
	KILIFI_KILIFI PS_220kV	1	20	5400	2560	6863
	KILIFI_KILIFI PS_220kV	2	20	0	2560	0
	MARIAKANI_KILIFI PS_400kV	1	100	32000	5000	9568
	MARIAKANI_KILIFI PS_400kV	2	100	0	5000	0
	MARIAKANI_DONGOKUNDU_400kV	1	40	12800	5000	9568

YEAR	TRANSMISSION LINE	CIRCUIT NO.	LENGTH (KM)	COST '000 USD		
				LINES	BAYS	NEW S/S
	MARIAKANI_DONGOKUNNDU_400kV	2	40	0	5000	0
	LANET_UPPLANDS_400kV	1	100	32000	4000	9568
	LANET_UPPLANDS_400kV	2	100	0	4000	0
	LANET_MENENGAI_400kV	1	20	6400	5000	9568
	LANET_MENENGAI_400kV	2	20	0	5000	0
	UPPLANDS_KIAMBУ NORTH_400kV	1	40	12800	4000	9568
	UPPLANDS_KIAMBУ NORTH_400kV	2	40	0	4000	
	ISINYA_MALILI_400kV***	1	0	0	4000	9568
	ISINYA_MALILI_400kV***	2	0	0	4000	0
	RUMURUTI_SUSWA_400kV***	1	0	0	4000	9568
	RUMURUTI_SUSWA_400kV***	2	0	0	4000	0
	RUMURUTI_LOYANGALANI_400kV***	1	0	0	4000	0
	RUMURUTI_LOYANGALANI_400kV***	2	0	0	4000	0
	MARSABIT_LOYANGALANI_400kV	1	200	40000	4000	0
	RONGAI_OLKARIA II_400kV***	1	0	0	5000	9568
	RONGAI_OLKARIA II_400kV***	2	0	0	5000	0
	RONGAI_LESSOS_400kV***	1	0	0	5000	9568
	RONGAI_LESSOS_400kV***	2	0	0	5000	0
2030	NYALI_BAMBURI_132kV	1	8	1258	1566	4193
	NYALI_BAMBURI_132kV	2	8	0	1566	0
	KAJIADO_ISINYA_132kV	1	10	968	1566	0
	MARIAKANI_MIRITINI_220kV	1	20	4400	2560	6863
	MARIAKANI_MIRITINI_220kV	2	20	0	2560	0
	ISINYA_KITENGELA_220kV*	1	0	0	4000	6863
	ISINYA_KITENGELA_220kV*	2	0		4000	0
	KITENGELA_ATHI_220kV*	1	0	0	4000	0
	KITENGELA_ATHI_220kV*	2	0		4000	0
	KAMBURU_EMBU_220kV	1	40	8800	2560	6863
	KAMBURU_EMBU_220kV	2	40	0	2560	0
	MATASIA_PIPELINE_220kV	1	10	2700	2560	6863
	MATASIA_PIPELINE_220kV	2	10	0	2560	0
	CITY SQR_LANGATA_220kV	1	15	20250	2560	6863
	CITY SQR_LANGATA_220kV	2	15	0	2560	0
	CITY SQR_NGONG RD_220kV	1	10	13500	2560	6863
	CITY SQR_NGONG RD_220kV	2	10	0	2560	0

YEAR	TRANSMISSION LINE	CIRCUIT NO.	LENGTH (KM)	COST '000 USD		
				LINES	BAYS	NEW S/S
	ELDORET N_KITALE_220kV	1	60	9600	2560	0
	KOMOROCK_KANGUNDO_220kV	1	40	10800	2560	6863
	KOMOROCK_KANGUNDO_220kV	2	40	0	2560	0
	NBNORTH_UPLANDS_220kV	1	30	8100	2560	0
	NBNORTH_UPLANDS_220kV	2	30	0	2560	0
	RABAI_MALINDI_220kV	1	97	15520	2560	0
	DRIVE INN_RUARAKA_220kV	1	10	2700	2560	6863
	DRIVE INN_RUARAKA_220kV	2	10	0	2560	0
	LESSOS_ELDORET SOUTH_220kV	1	22	0	2560	6863
	CHEMOSIT_KISII_220kV	1	60	13200	2560	6863
	CHEMOSIT_KISII_220kV	2	60		2560	0
	MTITO ANDEI_SULTAN_220kV	1	129	34830	2560	6863
	MTITO ANDEI_SULTAN_220kV	2	129	0	2560	0
	MTITO ANDEI_VOI_220kV	1	90	24300	2560	6863
	MTITO ANDEI_VOI_220kV	2	90	0	2560	0
	GARSEN_LAMU_220kV	1	108	17280	2560	0
	KANGUNDO_KAMULU_220kV	1	30	8100	2560	6863
	KANGUNDO_KAMULU_220kV	2	30	0	2560	0
	KANGUNDO_KATANI_220kV	1	30	8100	2560	6863
	KANGUNDO_KATANI_220kV	2	30	0	2560	0
	MALILI_MACHAKOS_220kV	1	30	6600	2560	6863
	MALILI_MACHAKOS_220kV	2	30	0	2560	0
	MALILI_SULTAN_220kV	1	50	13500	2560	6863
	MALILI_SULTAN_220kV	2	50	0	2560	0
	MARIKANI_VOI_220kV	1	114	30780	2560	6863
	MARIKANI_VOI_220kV	2	114	0	2560	0
	NAKURU SOUTH_RONGAI_220kV	1	20	4400	2560	6863
	NAKURU SOUTH_RONGAI_220kV	2	20	0	2560	0
	NGONG_KIKUYU_220kV	1	20	5400	2560	6863
	NGONG_KIKUYU_220kV	2	20	0	2560	0
	NGONG_LAVINGTON_220kV	1	40	10800	2560	6863
	NGONG_LAVINGTON_220kV	2	40	0	2560	0
	KILIFI_BAMBURI_220kV	1	50	13500	2560	6863
	KILIFI_BAMBURI_220kV	2	50	0	2560	0
	KILIFI PS_MALINDI_400kV	1	75	24000	5000	9568
	KILIFI PS_MALINDI_400kV	2	75	0	5000	0

YEAR	TRANSMISSION LINE	CIRCUIT NO.	LENGTH (KM)	COST '000 USD		
				LINES	BAYS	NEW S/S
	MALINDI_LAMU_400kV	1	225	72000	4000	9568
	MALINDI_LAMU_400kV	2	225	0	4000	0
	KANGUNDO THIKA_400kV	1	60	19200	4000	9568
	KANGUNDO THIKA_400kV	2	60	0	4000	0
	KANGUNDO_KITUI_400kV	1	90	28800	5000	0
	KANGUNDO_KITUI_400kV	2	90	0	5000	0
	KANGUNDO_MALILI_400kV	1	50	16000	4000	0
	KANGUNDO_MALILI_400kV	2	50	0	4000	
	THIKA_LAMU_400kV	1	550	176000	5000	0
	THIKA_LAMU_400kV	2	550	0	5000	0
	THIKA_KIAMBУ NORTH_400kV	1	40	12800	4000	9568
	THIKA_KIAMBУ NORTH_400kV	2	40	0	4000	0
	THIKA_RUMURUTI_400kV	1	200	64000	4000	0
	THIKA_RUMURUTI_400kV	2	200	0	4000	0
	SILALI_LESSOS_400kV	1	160	51200	4000	0
	SILALI_LESSOS_400kV	2	160	0	4000	0
	RUMURUTI_BOGORIA_400kV	1	100	32000	4000	0
	RUMURUTI_BOGORIA_400kV	2	100	0	4000	0
	KITUI_MALILI_400kV	1	50	16000	5000	0
	KITUI_MALILI_400kV	2	50		5000	
	KISUMU EAST_LESSOS_400kV***	1	0	0	4000	9568
	KISUMU EAST_LESSOS_400kV***	2	0	0	4000	0
	SUSWA_NGONG_400kV*	1	0	0	4000	9568
	SUSWA_NGONG_400kV*	2	0	0	4000	0
	PIPELINE_NGONG_400kV*	1	0	0	4000	0
	PIPELINE_NGONG_400kV*	2	0	0	4000	0
2033	ISINYA_KAJIADO WIND_220kV	1	30	6600	2560	0
	ISINYA_KAJIADO WIND_220kV	2	30	0	2560	0
	KAMBURU_KARURA_220kV*	1	0	0	2560	0
	KIAMBERE_KARURA_220kV*	2	0	0	2560	0
	ELDORET NORTH_ELDORET_220kV	2	10	1600	2560	0
	NGONG RD_LAVINGTON_220kV	1	10	13500	2560	6863
	NGONG RD_LAVINGTON_220kV	2	10	0	2560	0
	JUJA_MANGU_220kV	1	10	2700	2560	6863
	JUJA_MANGU_220kV	2	10	0	2560	0
	LESSOS_ELDORET_220kV	2	30	4800	2560	0

YEAR	TRANSMISSION LINE	CIRCUIT NO.	LENGTH (KM)	COST '000 USD		
				LINES	BAYS	NEW S/S
	KISII_AWENDO_220kV	1	44	9680	2560	6863
	KISII_AWENDO_220kV	2	44	0	2560	0
	KILIFI_MTWAPA_220Kv*	1	0	0	2560	6863
	KILIFI_MTWAPA_220kV*	2	0	0	2560	0
	BAMBURI_MTWAPA_220kV*	1	0	0	2560	0
	BAMBURI_MTWAPA_220kV*	2	0	0	2560	0
	KILIFI PS_MATSANGONI_400kV	1	30	9600	4000	0
	KILIFI PS_MATSANGONI_400kV	2	30	0	4000	0
	KISUMU EAST_SIRONGO NP_400kV	1	75	24000	5000	0
	KISUMU EAST_SIRONGO NP_400kV	2	75	0	5000	
	SILALI_EMURUANGALANG_400kV	1	40	12800	4000	0
	SILALI_EMURUANGALANG_400kV	2	40	0	4000	0
	EMURUANGALANG_BARRIER_400kV	1	80	25728	4000	0
	EMURUANGALANG_BARRIER_400kV	2	80	0	4000	0
	MARSABIT_LOYANGALANI_400kV	2	200	40000	4000	0

Key

*Transmission line sectionalizing and termination to establish a substation or switching station

** 400 kV line construction for initial operation at 220 kV

*** Conversion from 220 kV operation to 400kV operation (400/220 kV substation)

Table 8: TRANSFORMERS INVESTMENT SEQUENCE

	SS/TRANSFORMERS	CIRCUIT NO	CAPACITY MVA	COST 000 USD	
2014	OLKARIA IE_132_220kV	1	150		2014
	OLKARIA IE_132_220kV	2	150		2014
	MUHORONI_132_33kV	1	23		781
	BAMBURI_132_33kV	2	45		1040
	SONDU_132_33kV	1	23		781
	NAKURU WEST_132_33kV	1	23		781
	NAKURU WEST_132_33kV	2	23		781
	AWENDO_132_33kV	1	23		781
	KITALE_132_33kV	1	23		781
	MWINGI_132_33kV	1	23		781
	GARISSA_132_33kV	1	23		781
	KAINUK_220_66kV	1	45		1040
	LESSOS_220_132kV	3	75		1408

	SS/TRANSFORMERS	CIRCUIT	CAPACITY	COST
		NO	MVA	000 USD
	LESSOS_220_132kV	4	75	1408
	NGONG_220_66kV	1	200	2686
	NGONG_220_66kV	2	200	2686
	ATHI_220_66kV	1	200	2686
	ATHI_220_66kV	2	200	2686
2015	MTWAPA_132_33kV	1	45	1235
	MTWAPA_132_33kV	2	45	1235
	ELDORET_132_33kV	1	45	1235
	ELDORET_132_33kV	2	45	1235
	KISUMU_132_33kV	1	90	1950
	KISUMU_132_33kV	2	90	1950
	CHEMOS_132_33kV	1	45	1040
	CHEMOS_132_33kV	2	45	1040
	KIGANJ0_132_220kV	1	45	1040
	KIGANJ0_132_220kV	2	45	1040
	KILIFI_132_33kV	1	23	781
	CHOGORIA_132_33kV	1	15	509
	LANET_132_33kV	1	90	1950
	LANET_132_33kV	2	90	1950
	SULTAN_132_33kV	1	23	255
	GALU_132_33kV	1	23	781
	KYENI_132_33kV	1	23	781
	BOMET_132_33kV	1	23	781
	NYAHURURU_132_33kV	1	23	781
	KABARNET_132_33kV	1	23	781
	WAJIR_132_33kV	1	23	781
	KAJIADO_132_33kV	1	23	781
	KITALE_132_220kV	1	150	2014
	ORTUM_220_33	1	23	906
	MARALAL_132_33kV	1	7.5	255
	NAROK_132_33kV	1	23	781
	WOTE_132_33kV	1	23	255
	ISIOLO_132_33kV	1	23	781
	KITUI_132_33kV	1	23	781
	NAMANGA_132_33kV	1	23	781
	MACHAKOS_132_33kV	1	23	781
	ISIBENIA_132_33kV	1	23	781
	LUNGA LUNGA_132_33kV	1	15	509

	SS/TRANSFORMERS	CIRCUIT	CAPACITY	COST
		NO	MVA	000 USD
	MAUA_132_33kV	1	15	509
	KOMOROCK_220_66kV	1	200	2686
	KOMOROCK_220_66kV	2	200	2686
	THIKA RD_220_66kV	1	200	2686
	THIKA RD_220_66kV	2	200	2686
	HOLA_220_33kV	1	7.5	206
2020	MARIKANI_400_220kV	1	350	4700
	MARIKANI_400_220kV	2	350	4700
	ISINYA_400_220kV	1	350	4700
	ISINYA_400_220kV	2	350	4700
	ISINYA_400_220kV	3	350	4700
	SUSWA_400_220kV	1	350	4700
	SUSWA_400_220kV	2	350	4700
	SUSWA_400_220kV	3	350	4700
	PIPELINE_400_220kV	1	350	4700
	PIPELINE_400_220kV	2	350	4700
	KINDARUMA_132_33kV	1	23	529
	KIPEVU_132_33kV	1	200	2686
	KIPEVU_132_33kV	2	200	2686
	KIPEVU_132_33kV	3	200	2686
	JUJA RD_132_220kV	1	350	4375
	JUJA RD_132_220kV	2	350	4375
	1JUJA RD_132_66kV	1	150	2014
	JUJA RD_132_66kV	2	150	2014
	JUJA RD_132_66kV	3	150	2014
	ELDORET_132_220kV	1	150	2014
	ELDORET_132_220kV	2	150	2014
	ELDORET_132_33kV	1	45	1040
	ELDORET_132_33kV	2	45	1040
	KISUMU_132_220kV	1	150	2014
	KISUMU_132_220kV	2	150	2014
	1KISUMU_132_220kV	3	150	2014
	CHEMOS_132_220kV	1	150	2014
	CHEMOS_132_220kV	2	150	2014
	1CHEMOS_132_220kV	3	150	2014
	NANYUKI_132_33kV	1	23	781
	KILIF1_132_33kV	1	45	1040
	KILIF1_132_33kV	2	45	1040

	SS/TRANSFORMERS	CIRCUIT	CAPACITY	COST
		NO	MVA	000 USD
	1MUSAG_132_220kV	1	150	2014
	1MUSAG_132_220kV	2	150	2014
	LESSOS_132_33kV	1	150	2014
	LANET_132_220kV	1	150	2014
	LANET_132_220kV	2	150	2014
	1NAIVSH_132_220kV	1	150	2014
	1NAIVSH_132_220kV	2	150	2014
	NAIVSHA_132_33kV	1	45	1040
	NAIVSHA_132_33kV	2	45	1040
	MARIKANI_132_220kV	1	150	2014
	MARIKANI_132_220kV	2	150	2014
	RUARAKA_132_220kV	1	350	4375
	RUARAKA_132_220kV	2	350	4375
	RUARAKA_132_66kV	1	150	2014
	RUARAKA_132_66kV	2	150	2014
	RUARAKA_132_66kV	1	150	2014
	GALU_132_33kV	1	90	1950
	GALU_132_33kV	2	90	1950
	KYENI_132_33kV	2	23	781
	SONDU_132_33kV	2	23	781
	KUTUS_132_33kV	1	90	1950
	KUTUS_132_33kV	2	90	1950
	BOMET_132_33kV	2	23	532
	KISII_132_33kV	1	45	1040
	KISII_132_33kV	2	45	1040
	KAJIADO_132_33kV	1	45	1040
	KAJIADO_132_33kV	2	45	1040
	NAKURU WEST_132_33kV	1	45	1040
	NAKURU WEST_132_33kV	2	45	1040
	RUMURUTI_132_33kV	1	90	1950
	KITALE_132_220kV	1	150	2014
	KITALE_132_33kV	2	23	781
	GITHAMBO_132_33kV	2	23	781
	GARISSA_132_220kV	1	23	781
	GARISSA_132_33kV	2	23	781
	MACHAKOS_132_33kV	2	23	781
	HOMABAY_132_33kV	2	23	781
	MATASIA_220_66kV	1	200	2686
	MATASIA_220_66kV	2	200	2686

	SS/TRANSFORMERS	CIRCUIT	CAPACITY	COST
		NO	MVA	000 USD
	MATASIA_220_66kV	3	200	2686
	LIKONI_220_33kV	1	90	1950
	LIKONI_220_33kV	2	90	1950
	ELDORET NORTH_220_33kV	1	90	1950
	ELDORET NORTH_220_33kV	2	90	1950
	KOMOROCK_220_66kV	1	200	2686
	EMBAKASI_220_66kV	1	200	2686
	EMBAKASI_220_66kV	2	200	2686
	EMBAKASI_220_66kV	3	200	2686
	NBNORTH_220_66kV	1	200	2686
	NBNORTH_220_66kV	2	200	2686
	RABAI_220_132kV	1	350	4375
	RABAI_220_132kV	2	350	4375
	KISUMU EAST_220_33kV	1	45	1040
	KISUMU EAST_220_33kV	1	45	1040
	NGONG_220_66kV	3	200	2686
	RONGAI_220_33kV	1	90	1950
	RONGAI_220_33kV	2	90	1950
	RONGAI_220_400kV	1	750	7650
	KAPSOWAR_33_132kV	1	23	781
	CHAVAKALI_33_132kV	1	23	781
	GILGIL_33_132kV	1	23	781
2025	MARIKANI_400_220kV	3	350	4700
	KIAMBУ NORTH_400_220kV	1	500	5100
	KIAMBУ NORTH_400_220kV	2	500	5100
	MALILI_400_220kV	1	350	4700
	MALILI_400_220kV	2	350	4700
	MALILI_400_220kV	3	350	4700
	MANGU_132_220kV	1	150	2014
	JUJA RD_132_220kV	1	350	4700
	JUJA RD_132_220kV	2	350	4700
	JUJA RD_132_66kV	1	200	2686
	JUJA RD_132_66kV	2	200	2686
	JUJA_132_66kV	3	200	2686
	ELDORET_132_33kV	1	90	1950
	ELDORET_132_33kV	2	90	1950
	1MUHORN_132_220kV	1	90	1950
	MUHORN_132_33kV	2	90	1950

	SS/TRANSFORMERS	CIRCUIT	CAPACITY	COST
		NO	MVA	000 USD
	CHEMOSIT_132_220kV	1	150	2014
	CHEMOSIT_132_33kV	1	90	1950
	CHEMOSIT_132_33kV	2	90	2080
	KIGANJO_132_220kV	1	150	2014
	KIGANJO_132_220kV	2	150	2014
	KIGANJO_132_33kV	1	90	1950
	KIGANJO_132_33kV	2	90	1950
	NANYUKI_132_220kV	1	150	2014
	NANYUKI_132_220kV	2	150	2014
	NANYUKI_132_33kV	1	45	1040
	NANYUKI_132_33kV	2	45	1040
	KILIFI_132_220kV	1	200	2686
	KILIFI_132_220kV	2	200	2686
	KILIFI_132_33kV	3	90	2080
	KILIFI_132_33kV	1	90	2080
	BAMBURI_132_33kV	1	90	1950
	BAMBURI_132_33kV	2	90	1950
	MUSAGA_132_33kV	1	45	1040
	MUSAGA_132_33kV	2	45	1040
	LANET_132_33kV	1	200	2686
	LANET_132_33kV	2	200	2686
	NAIVSH_132_33kV	1	90	1950
	NAIVSH_132_33kV	2	90	1950
	SULTAN_132_33kV	1	15	509
	GALU_132_33kV	1	200	2686
	GALU_132_33kV	2	200	2686
	GALU_132_220kV	1	200	2686
	GALU_132_220kV	2	200	2686
	KYENI_132_33kV	1	23	781
	MERU_132_220kV	1	200	2686
	MERU_132_220kV	2	200	2686
	BOMET_132_33kV	1	45	1040
	BOMET_132_33kV	2	45	1040
	KISII_132_33kV	1	45	1040
	KISII_132_33kV	2	45	1040
	KAJIADO_132_33kV	1	90	1950
	KAJIADO_132_33kV	2	90	1950
	GATUNDU_132_33kV	1	23	781
	GITHAMBO_132_33kV	1	45	1040

	SS/TRANSFORMERS	CIRCUIT	CAPACITY	COST
		NO	MVA	000 USD
	GITHAMBO_132_33kV	2	45	1040
	NAROK_132_33kV	1	23	781
	WOTE_132_33kV	1	7.5	255
	MURANGA_132_220kV	1	90	1950
	MURANGA_132_220kV	2	90	1950
	ISIOLO_132_220kV	1	150	2014
	ISIOLO_132_220kV	2	150	2014
	ISIOLO_132_33kV	1	23	781
	ISIOLO_132_33kV	2	23	781
	KITUI_132_33kV	1	45	1040
	KITUI_132_33kV	2	45	1040
	MACHAKOS_132_33kV	1	45	1040
	MACHAKOS_132_33kV	2	45	1040
	HOMABAY_132_220kV	1	23	781
	DONGOKUNDU_220_400kV	1	750	7650
	DONGOKUNDU_220_400kV	1	750	7650
	LIKONI_220_33kV	1	200	2686
	LIKONI_220_33kV	2	200	2686
	OLKARIA II_220_400kV	1	350	4700
	OLKARIA II_220_400kV	2	350	4700
	CITY SQR_220_66kV	1	350	4700
	CITY SQR_220_66kV	2	350	4700
	CITY SQR_220_66kV	3	350	4700
	LANGATA_220_66kV	1	350	4700
	LANGATA_220_66kV	2	350	4700
	MBARAKI_220_33kV	1	200	2686
	MBARAKI_220_33kV	2	200	2686
	LESSOS_220_400kV	1	350	4700
	LESSOS_220_400kV	2	350	4700
	LESSOS_220_132kV	1	75	1750
	LESSOS_220_132kV	2	75	1750
	MALINDI_220_33kV	1	45	1040
	MALINDI_220_33kV	2	45	1040
	LAMU_220_33kV	1	45	1040
	LAMU_220_33kV	2	45	1040
	KIAMBУ NORTH_220_66kV	1	350	4700
	KIAMBУ NORTH_220_66kV	2	350	4700
	KAMULU_220_66kV	1	350	4700
	KAMULU_220_66kV	2	350	4700

	SS/TRANSFORMERS	CIRCUIT	CAPACITY	COST
		NO	MVA	000 USD
	ATHI_220_66kV	1	200	2686
	ATHI_220_66kV	2	200	2686
	RONGAI_220_400kV	1	750	7650
	RONGAI_220_400kV	2	750	7650
	CHAVAKALI_33_132kV	1	23	781
2030	MALINDI_400_220kV	1	350	4700
	MALINDI_400_220kV	2	350	4700
	KANGUNDO_400_220kV	1	500	5100
	KANGUNDO_400_220kV	2	500	5100
	KANGUNDO_400_220kV	3	500	5100
	THIKA_400_220kV	1	750	7650
	THIKA_400_220kV	2	750	7650
	THIKA_400_220kV	3	750	7650
	LAMU_400_220kV	1	350	4700
	LAMU_400_220kV	2	350	4700
	UPLANDS_400_220kV	1	350	4700
	UPLANDS_400_220kV	2	350	4700
	ISINYA_400_220kV	3	350	4700
	KITUI_400_132kV	1	150	2014
	KISUMU EAST_400_220kV	1	500	5100
	KISUMU EAST_400_220kV	2	500	5100
	KISUMU EAST_400_220kV	3	500	5100
	PIPELINE_400_220kV	1	500	5100
	NGONG_400_220kV	1	750	7650
	NGONG_400_220kV	2	750	7650
	KITENGELA_220_66kV	1	200	2686
	KITENGELA_220_66kV	2	200	2686
	KITENGELA_220_66kV	3	200	2686
	NYALI_132_33kV	1	90	1950
	NYALI_132_33kV	2	90	1950
	KIPEVU_132_33kV	1	200	2686
	KIPEVU_132_33kV	2	200	2686
	KIPEVU_132_33kV	3	200	2686
	MANGU_132_66kV	1	200	2686
	MANGU_132_66kV	2	200	2686
	MTWAPA_132_33kV	1	90	1950
	MTWAPA_132_33kV	2	90	1950
	RABAI_132_33kV	1	90	1950

	SS/TRANSFORMERS	CIRCUIT	CAPACITY	COST
		NO	MVA	000 USD
	RABAI_132_33kV	2	90	1950
	MUHORN_132_220kV	1	200	2686
	MUHORN_132_220kV	2	200	2686
	MUHORN_132_33kV	1	90	1950
	KISUMU_132_33kV	1	200	2686
	KISUMU_132_33kV	2	200	2686
	KIGANJ0_132_33kV	1	200	2686
	KIGANJ0_132_33kV	2	200	2686
	CHOGORIA_132_33kV	2	15	509
	BAMBURI_132_220kV	1	200	2686
	BAMBURI_132_220kV	2	200	2686
	LESSOS_132_33kV	1	45	1040
	LESSOS_132_33kV	2	45	1040
	SULTAN_132_220kV	1	150	2014
	SULTAN_132_33kV	2	15	509
	MTITO ANDEI_132_220kV	1	150	2014
	VOI_132_220kV	1	150	2014
	RUARAKA_132_66kV	1	350	4700
	RUARAKA_132_66kV	2	350	4700
	KAPSABET_132_33kV	1	23	781
	KAPSABET_132_33kV	2	23	781
	GALU_132_400kV	1	350	4700
	KYENI_132_33kV	1	45	1040
	KYENI_132_33kV	2	45	1040
	SONDU_132_33kV	1	23	781
	KUTUS_132_220kV	1	200	2686
	KUTUS_132_220kV	2	200	2686
	KUTUS_132_33kV	1	90	1950
	KUTUS_132_33kV	2	90	1950
	BOMET_132_33kV	1	90	1950
	NYAHURURU_132_33kV	1	23	781
	KISII_132_220kV	1	150	2014
	KISII_132_220kV	2	150	2014
	KISII_132_33kV	1	90	1209
	KISII_132_33kV	2	90	1209
	RANGALA_132_33kV	1	45	1040
	KITALE_132_33kV	1	90	1950
	KITALE_132_33kV	2	90	1950
	NAROK_132_33kV	1	23	781

	SS/TRANSFORMERS	CIRCUIT	CAPACITY	COST
		NO	MVA	000 USD
	WOTE_132_33kV	1	23	781
	ISIOLO_132_33kV	1	45	1040
	ISIOLO_132_33kV	2	45	1040
	MACHAKOS_132_220kV	1	200	2686
	MACHAKOS_132_33kV	1	150	2014
	MACHAKOS_132_33kV	2	150	2014
	HOMABAY_132_220kV	1	90	1950
	HOMABAY_132_220kV	2	90	1950
	DONGOKUNDU_220_33kV	1	200	2686
	DONGOKUNDU_220_33kV	1	200	2686
	DONGOKUNDU_220_400kV	2	750	7650
	MATASIA_220_66kV	1	350	4700
	MATASIA_220_66kV	2	350	4700
	MATASIA_220_66kV	3	350	4700
	ELDORET N_220_33kV	1	200	2686
	1EMBAK2_220_66kV	1	350	4700
	1EMBAK2_220_66kV	2	350	4700
	NGONG RD_220_66kV	1	350	4700
	NGONG RD_220_66kV	2	350	4700
	MBARAKI_220_33kV	1	200	2686
	DRIVE INN_220_66kV	1	350	4700
	DRIVE INN_220_66kV	2	350	4700
	MIRITINI_220_33kV	1	350	4700
	MIRITINI_220_33kV	2	350	4700
	KISUMU E_220_33kV	1	150	2014
	KISUMU E_220_33kV	2	150	2014
	1LESSO2_220_400kV	1	500	5100
	1LESSO2_220_132kV	2	200	2686
	MALINDI_220_33kV	1	200	2686
	MALINDI_220_33kV	2	200	2686
	LAMU_220_33kV	1	90	1950
	LAMU_220_33kV	2	90	1950
	THIKA_220_66kV	1	200	2686
	THIKA_220_66kV	2	200	2686
	NAKURU S_220_33kV	1	200	2686
	NAKURU S_220_33kV	2	200	2686
	THIKA RD_220_66kV	1	350	4700
	THIKA RD_220_66kV	2	350	4700
	HOLA_220_33kV	1	23	781

	SS/TRANSFORMERS	CIRCUIT	CAPACITY	COST
		NO	MVA	000 USD
	CHAVAKALI_33_132kV	1	45	1040
	KATANI_66_220kV	1	200	2686
	KATANI_66_220kV	2	200	2686
	KATANI_66_220kV	3	200	2686
	ELDORET S_33_220kV	1	200	2686
	ELDORET S_33_220kV	2	200	2686
	KIKUYU_66_220kV	1	350	4700
	KIKUYU_66_220kV	2	350	4700
	LAVINGTON_66_220kV	1	350	4700
	LAVINGTON_66_220kV	2	350	4700
2033	MARIAKANI_400_220kV	1	500	5100
	MARIAKANI_400_220kV	2	500	5100
	MARIAKANI_400_220kV	3	500	5100
	KILIFI PS_400_220kV	1	500	5100
	KILIFI PS_400_220kV	2	500	5100
	KANGUNDO_400_220kV	3	500	5100
	UPLANDS_400_220kV	3	350	4700
	ISINYA_400_220kV	1	500	5100
	ISINYA_400_220kV	2	500	5100
	ISINYA_400_220kV	2	500	5100
	ISINYA_400_220kV	4	500	5100
	KITUI_400_132kV	1	150	2014
	PIPELINE_400_220kV	3	500	5100
	NGONG_400_220kV	3	750	7650
	ISINYA_220_132kV	1	350	4700
	ISINYA_220_132kV	2	350	4700
	NYALI_132_33kV	2	200	2686
	JUJA RD_132_66kV	1	200	2686
	1JUJA RD_132_66kV	2	200	2686
	ELDORET_132_33kV	1	150	2014
	ELDORET_132_33kV	2	150	2014
	MUHORNI_132_33kV	1	200	2686
	MUHORNI_132_33kV	2	200	2686
	KISUMU_132_220kV	1	350	4700
	KISUMU_132_220kV	2	350	4700
	KISUMU_132_220kV	3	200	2686
	KISUMU_132_33kV	1	200	2686
	CHEMOS_132_33kV	2	200	2686

	SS/TRANSFORMERS	CIRCUIT	CAPACITY	COST
		NO	MVA	000 USD
	CHEMOS_132_33kV	2	200	2686
	KIGANJ_132_220kV	1	350	4700
	KIGANJ_132_220kV	2	350	4700
	NANYUKI_132_33kV	1	90	1950
	NANYUKI_132_33kV	1	90	1950
	KILIFI_132_220kV	2	200	2686
	KILIFI_132_33kV	1	200	2686
	KILIF1_132_33kV	2	200	2686
	BAMBURI_132_33kV	1	200	2686
	BAMBURI_132_33kV	2	200	2686
	MUSAGA_132_33kV	1	90	1950
	MUSAGA_132_33kV	2	90	1950
	LESSOS_132_33kV	1	90	1950
	LESSOS_132_33kV	2	90	1950
	LANET_132_220kV	1	200	2686
	LANET_132_220kV	2	200	2686
	LANET_132_220kV	3	200	2686
	NAIVSH_132_33kV	1	200	2686
	NAIVSH_132_33kV	2	200	2686
	SULTAN_132_33kV	1	23	781
	SULTAN_132_33kV	2	23	781
	MARIKANI_132_220kV	1	350	4700
	MARIKANI_132_220kV	2	350	4700
	KAPSABET_132_33kV	1	45	1040
	KAPSABET_132_33kV	2	45	1040
	GALU_132_400kV	1	350	4700
	KUTUS_132_33kV	1	200	2686
	KUTUS_132_33kV	2	200	2686
	MERU_132_33kV	1	90	1950
	MERU_132_33kV	2	90	1950
	BOMET_132_33kV	1	90	1950
	NYAHURURU_132_33kV	1	45	1040
	NYAHURURU_132_33kV	2	45	1040
	KABARNET_132_33kV	2	23	781
	KAJIADO_132_33kV	1	90	1950
	AWENDO_132_33kV	2	23	781
	RANGALA_132_33kV	2	45	1040
	GATUNDU_132_33kV	1	45	1040
	GATUNDU_132_33kV	1	45	1040

	SS/TRANSFORMERS	CIRCUIT	CAPACITY	COST
		NO	MVA	000 USD
	GITHAMBO_132_33kV	1	90	1950
	GITHAMBO_132_33kV	2	90	1950
	MAKUTANO_132_33kV	2	23	781
	GARISSA_132_33kV	1	45	1040
	GARISSA_132_33kV	2	45	1040
	ISIOLO_132_33kV	1	90	1950
	ISIOLO_132_33kV	2	90	1950
	HOMABAY_132_33kV	1	45	1040
	HOMABAY_132_33kV	2	45	1040
	LUNGA LUNGA_132_33kV	2	15	509
	MAUA_132_33kV	2	15	509
	DONGOKUN_220_400kV	3	750	7650
	OLLARIA II_220_400kV	3	350	4700
	KOMOROCK_220_66kV	1	500	5100
	KOMOROCK_220_66kV	2	500	5100
	KOMOROCK_220_66kV	3	500	5100
	NBNORTH_220_66kV	1	350	4700
	NBNORTH_220_66kV	2	350	4700
	RABAI_220_132kV	3	350	4700
	JUJA_220_66kV	1	350	4700
	JUJA_220_66kV	2	350	4700
	LESSOS_220_400kV	1	500	5100
	LESSOS_220_400kV	2	500	5100
	LESSOS_220_132kV	1	90	1950
	LESSOS_220_132kV	2	90	1950
	LESSOS_220_132kV	3	200	2686
	RONGAI_220_33kV	1	200	2686
	RONGAI_220_33kV	2	200	2686
	CHAVAKALI_33_132kV	1	90	1950
	CHAVAKALI_33_132kV	2	90	1950
	GILGIL_33_132kV	2	23	781
	MTWAPA_33_220kV	1	200	2686
	MTWAPA_33_220kV	2	200	2686

Table 9: REACTIVE COMPENSATION INVESTMENT SEQUENCE

YEAR	SUBSTATION	VOLTAGE KV	COMPENSATION	
			MVAR	COST '000 USD
2014	GARISSA	132	-7.5	83

YEAR	SUBSTATION	VOLTAGE KV	COMPENSATION		COST '000 USD
			MVAR	COST '000 USD	
	MARIAKANI	400	-65		670
2015	CHEMOSIT	33	12		313
	KIGANJO	33	12		313
	SUSWA	220	-100		1031
2020	ELDORET	33	10		261
	KISUMU	33	12		313
	KILIFI	33	12		313
	GALU	33	16		418
	RUARAKA	66	38		992
	NGONG	66	43		1122
	THIKA RD	66	80		2088
	MANGU	132	76		1984
	KIGANJO	132	53		1383
	LANET	132	10		261
	SONDU	132	-7.5		83
	GARISSA	132	-7.5		83
	SUSWA	220	-113		1254
	KILIFI PS	220	-70		777
	RUMURUTI	400	-222		2464
	MARSABIT	400	-67		744
	LOYANGALANI	400	-252		2797
2025	MARIAKANI	220	-180		1998
	KIPEVU	132	27		692
	LANET	132	10		261
	SULTAN	132	9.5		248
	WAJIR	132	-7.5		83
	HOMABAY	132	23.5		613
	SUSWA	220	-71		788
	CHEMOSIT	33	9		235
	KISII	33	9		235
	BOMET	33	25		653
	RUARAKA	66	80		2088
	JUJA RD	66	120		3132
	EMBAKASI	66	25		653
	JUJA RD	66	90		2349
	EMBAKASI	66	55		1436

YEAR	SUBSTATION	VOLTAGE KV	COMPENSATION		COST '000 USD
			MVAR	COST '000 USD	
2030	MARIAKANI	400	150		3915
	LAMU	400	240		6264
	KOROSI	400	240		6264
	MARIAKANI	220	-84		932
	ISINYA	220	180		4698
	KISUMU	132	64		1655
	CHEMOSIT	132	60		1566
	KIGANJO	132	12.5		319
	LANET	132	10		261
	GALU	132	-30		333
	BOMET	132	30		783
	KISII	132	16		422
	KITALE	132	16		407
	HOMABAY	132	4		88
	MATASIA	220	150		3915
	LANGATA	220	150		3915
	KOMOROCK	220	150		3915
	NGONG RD	220	150		3915
	RABAI	220	30		783
	DRIVE INN	220	150		3915
	KATHWANA	220	47		1214
	KIAMBУ NORTH	220	90		2349
	KAMULU	220	150		3915
	THIKA RD	220	150		3915
	JUJA RD	66	30		783
	EMBAKASI	66	30		783
	KIKUYU	220	90		2349
	LAVINGTON	220	90		2349
	KATANI	220	90		2349
2033	SUSWA	400	270		7047
	KIGANJO	132	140		3596
	LANET	132	10		261
	BOMET	132	30		783
	KISII	132	14		361
	RUMURUTI	132	12		313
	MURANGA	132	90		2349
	KARI WAIYAKI WAY	220	130		3393

YEAR	SUBSTATION	VOLTAGE KV	COMPENSATION		COST '000 USD
			MVAR	COST '000 USD	
	LANGATA	220	30		783
	KOMOROCK	220	30		783
	NGONG RD	220	30		783
	DRIVE INN	220	120		3132
	JUJA	220	180		4698
	KATHWANA	220	44		1135
	MANGU	220	270		7047
	KIAMBU NORTH	220	90		2349
	THIKA	220	270		7047
	MALILI	220	50		1305
	KAMULU	220	30		783
	THIKA RD	220	30		783
	RUARAKA	220	270		7047
	NGONG	220	270		7047
	UPLANDS	220	180		4698
	NAIVASHA	220	90		2349
	LESSOS	400	180		4698
	RUARAKA	66	30		783
	LAVINGTON	220	90		2349
	KATANI	220	40		1044

This study sought to update the 2011-2031 LCPDP taking into account changes in demand in line with anticipated macroeconomic performance, committed power generation and transmission projects and update the power system simulation data including plant types, system constraints and costs. ERC, MOE, KenGen, GDC, KNBS, REA, KETRACO, KNEB and KPLC staff participated actively in the studies and new team members received training in the operation of these models. MAED based excel worksheets were used for the development of electricity forecasts, VALORAGUA and WASP models were used to optimize the hydro-thermal generation mix of Kenya power system and select the least cost power plants to be added in future years while PSSE was used to determine the transmission system plan. The planning team reviewed the assumptions that were made in this study and ran additional sensitivity scenarios to test new inputs. From the study the following conclusions and recommendations emerge.

5.1 Conclusions

5.1.1 Load Forecasting

The load forecast was done using an excel model developed in 2011, but in this update, primary data collected through the AFD technical assistance was utilized. The excel model follows the MAED principles and assumptions which indicate that the nature and the level of demand for goods and services are driven by several determinants including; population, household size, specific consumption (kWh/household/year) and expected social and economic evolution of the country.

Based on the assumptions the load forecast indicates that the peak demand is estimated at 1370 MW in 2012 and in 2033, the peak demand grows to 11,318MW in low scenario, 21,075MW in reference scenario and 31,237MW in the high scenario. The energy demand increases from 8010GWh in 2012 to 17,719GWh in 2018 to 81,352GWh in 2030 and 118,680GWh in 2033. The current peak load is expected to grow 10 times by the year 2030.

There is a very slight difference between this and the load forecast done in the last update of 2011-2031. The reference peak demand for 2030 in the last update was 15,026MW which compares very closely to the peak demand projected in the current review, of 14,446MW.

5.1.2Least Cost Generation and Transmission plan

Using annual data for the last 30 years (1980-2009) VALORAGUA hydrothermal optimization indicated that the average hydro generation in Kenya is about 3,280GWh with the highest hydro generation being experienced in May during the long rains and the lowest in February. The study also found a strong inverse correlation between the SRMC of the system and energy generation from hydro power plants due to the substitution effect of thermal generation. SRMC varies from month to month ranging from a high of 36.3 US cents/kWh in February to a low of 11 US cents/kWh in May.

The optimal development program is dominated by Geothermal, Coal, GT(N-GAS), Nuclear and Wind. Geothermal resources are the choice for the future generating capacity in Kenya. The optimum solution indicates that geothermal capacity should be increased from the current 209MW to 7,264 MW in 2033 contributing 27% of the total energy required by the system. The present value of the total system expansion cost over the period 2013-2033 for the base case development plan amounts to US\$ 31.4 billion (committed projects excluded), expressed in constant prices at the beginning of 2012.

Using the least cost generation development plan, a transmission system plan was developed for the period beginning 2013 to 2033. The transmission development plan indicates the need to develop approximately 11,231km of new lines (18,173Circuits) by 2033 at an approximated present value cost of US\$ 3.55 Billion.

5.2 IMPLEMENTATION PLAN

5.2.1Medium term 2014-2018

Generation projects

1. Timely implementation of committed power generation projects in order to attain an additional capacity of at least 2,639MW by 2018. This will require an investment of approximately US\$ 6.5 billion.

Transmission projects

2. Timely implementation of 5,438Km of committed and proposed transmission lines by 2015. The total non-discounted cost of this project is approximately US\$ 2.1 Billion which include bays & sub stations, transformers and reactive compensation.

Load forecast

3. In order to develop an energy database for use in the complete MAED model a survey is required. ERC has already embarked on preparing the terms of reference and has initiated discussions with the KNBS on undertaking a national survey based on MAED model data requirements. World Bank has been approached for financing.
4. All the institutions involved in the LCPDP preparation; i.e. MOE, ERC, KPLC, KETRACO, GDC, REA, KNEB and KenGen should continue training the members of the planning team in their respective institutions.

Nuclear

5. KNEB shall undertake preparatory work for the nuclear power plant expected to come on stream in 2023. The completion of the prefeasibility study should give priority as this will give direction on the key activities that will require to be done to have a plant by the year 2023.
6. KNEB should develop a clear programme of action showing the activities to be undertaken to deliver the nuclear power plant by the year 2023.

Coal

7. In order to realize the development of first 300 MW coal plant by the year 2024; KETRACO/KPLC should float tenders for the development of the coal plant latest by 2015 to accommodate a 4 year construction period.
8. Ministry of Energy & Petroleum shall continue exploration and subsequent mining of local coal to meet the high demand for coal arising from the proposed coal plants of up to 5400MW. The coal plants proposed in the plan will be located in the Mwingi/Kitui area to minimize transportation costs.

Geothermal

9. Geothermal Development Company shall develop and implement a rigorous monitoring and evaluation framework for the Geothermal Development Plan of drilling at least 1,200 wells to provide steam to the planned 5,880MW of new capacity by 2033. Timely implementation of the drilling programme is vital for the realization of this least cost generation

plan since the commissioning of the proposed geothermal plants track the drilling plan.

10. GDC should strictly implement the plans to start drilling the Bogoria/Silali in 2013/14 as planned. Any delays in this will affect the implementation of the generation projects planned for 2017.
11. Geothermal Development Company shall immediately invite Expressions of Interest from companies willing to develop power plants and well head generating units in line with the drilling plan. This will ensure that for every well drilled a company will be in line to develop a plant and hence avoiding delays in the projects implementation.

Hydro

12. MOEP should get information on all hydro projects being proposed by other government agencies for implementation for consideration in the next LCPDP update.

5.2.2 Long term 2018-2033

Geothermal

13. In order to ensure continuity in drilling until the full geothermal potential of 10,000MW is achieved GDC shall prepare a drilling plan for completion of drilling in the remaining sites by the year 2020. The Current drilling plan will also continue being adhered to strictly.

Nuclear

14. In order for the first 600MW nuclear plant to be commissioned by 2023, the following will require to be done:
 - o Establish a legal framework that will see the establishment of the Nuclear Regulatory Authority
 - o The Nuclear Regulatory Authority will issue three licenses for the identified sites: a license to prepare the sites, a license to construct the plants and a license to operate the nuclear power plant,

respectively. The licensing process must be completed at least six years (2016) ahead of the commissioning dates.

- In the years when Nuclear is coming (i.e. 2023, 2030 and 2033) investment cost is very high. This requires preparedness in terms of sourcing for adequate financing.
15. Commission the first 600 MW nuclear plants in 2023 and issue necessary operating licenses for the other nuclear power plants.

Coal

16. The Ministry of Energy & Petroleum shall complete assessment and development of the coal resources in the Mui Basin and invite bids for the commencement of mining and exploitation of the resource by 2020
17. The tenders for the other coal plants will be advertised in 2022 for the remaining coal plants to be commissioned between 2027 and 2033. The coal plants will be located in Kitui/Mwingi area which is near the Mui basin.

Transmission System Development Plan

18. A total of 11,231 km of new lines (18,173 km new circuits) will be developed in the period of 2013-2033. The approximated discounted cost is US\$ 3.55 Billion.